Sanitary Permit and Report of Final Inspection

Oneida County Planning and Zoning, Rhinelander, Wisconsin. Private onsite wastewater treatment system. **Specimen layout: the boxes follow the county form but this is not a copy of it.**

PROPERTY		
OWNER Raymond C. and Margaret A. Ostrander	SITE ADDRESS 8815 Skein Lake Road, Minocqua	MAILING ADDRESS 1846 Hawkstone Drive, Madison, WI 53711
TOWN Minocqua	PARCEL NUMBER MI-2214-7	LEGAL DESCRIPTION Lot 7, Sundquist's Skein Lake Plat, Sec. 22, T39N, R6E

PERMIT		
COUNTY PERMIT NUMBER OC-16-0417	STATE SANITARY PERMIT NUMBER 716203	DATE ISSUED June 20, 2016
TYPE OF PERMIT Replacement of a failing system	REASON Steel tank, 1958, failed inspection of June 6, 2016	FEE PAID $425.00

SYSTEM		
BUILDING SERVED One-family dwelling, seasonal	BEDROOMS 3	DESIGN FLOW 450 gallons a day
TYPE OF SYSTEM Mound, pressure distribution	SEPTIC TANK 1,000 gallons, concrete, with effluent filter	PUMP CHAMBER 500 gallons, with high-water alarm
DISTRIBUTION CELL 6 ft by 75 ft	DISTANCE FROM THE LAKE 112 ft to the ordinary high-water mark; 75 ft required	DISTANCE FROM THE WELL 84 ft; 50 ft required

PEOPLE		
SOIL TESTER Lyle Ahonen, CST 224018	DESIGNER Lyle Ahonen	INSTALLER Kangas Excavating & Septic, Wayne Kangas
INSTALLER'S LICENSE MPRS 228866		

FINAL INSPECTION		
DATE INSPECTED August 26, 2016	RESULT Approved	INSPECTOR D. Brandner
ALARM TESTED Yes: red light and buzzer on the post at the pump chamber	AS-BUILT PLAN FILED Yes	

MAINTENANCE REQUIRED BY THE COUNTY

INSPECTION AND PUMPING	REPORT	FIRST REPORT DUE
At least once every 3 years, by a licensed pumper	**The pumper files it with the county within 30 days**	**August 2019**
EFFLUENT FILTER	MOUND	
Rinse when the tank is pumped	**Keep vehicles and trees off; mow**	

The owner must keep this permit. A system that is not reported on time is treated as failing until it is inspected.